

**CITY OF DAHLONEGA
INVITATION TO BID**

**ASPHALT LEVELING AND RESURFACING
CITY STREETS IN DAHLONEGA, GEORGIA
LMIG PROJECT #2017-001**

ADDENDUM NUMBER 1

This addendum provides answers to questions submitted by potential bidders.

1. Can the City provide us with a breakdown of how many tons of Leveling will go on each street? **No**
2. Can the City tell us how thick they are planning to place the Leveling surface? **35 lbs per square**
3. Will the City allow the contractor to use Advance Warning Signs on tripods? Or will the City require the signs be post mounted? **Temporary signs will be allowed. Low and Soft Shoulder signs must be furnished and installed by the contractor as stated in section 150.**
4. Will the City require the Contractor to pave back to the radius points at side streets and driveways? Or are we to pave straight through them? **Pave straight through with lips on all drives and side roads. Only an intersection where not doing so will cause a problem will be paved back.**
5. Will the City or the contractor be responsible for adjusting manholes? **City of Dahlonega will adjust the manholes.**
6. What are the working hours for the Asphalt Leveling and Resurfacing Project for the City? **Daylight hours with no work on Sunday.**
7. Will the City add a pay item for the stop bars instead of including them in a long line striping item so the contractor will be paid per stop bar put down? **No**
8. Will the City be responsible for the adjustment of manholes and water valves? **Yes**
9. Does the City want 9.5MM Type 1 for the leveling? **Yes**